

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO-0121975

Owner: Struckhoff Sanitary Landfill, LLC c/o John Struckhoff
Address: 1465 Rock Lane, Washington, MO 63090

Continuing Authority: Same as above
Address: Same as above

Facility Name: Washington SLF Silt Pond
Facility Address: 925 Struckhoff Lane, Washington, MO 63090

Legal Description: NE ¼, NW ¼, Sec.8, T44N, R1W, Franklin County
Latitude/Longitude: +38.58708/-091.06008

Receiving Stream: Tributary to St. Johns Creek (C)
First Classified Stream and ID: Tributary to St. Johns Creek (C) (ID #3337)
USGS Basin & Sub-watershed No.: (10300200-110002)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 – Landfill Silt Pond - SIC #4953
Stormwater run-off settling basin.
Design flow is 80.0 million gallons per day.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

May 26, 2006
Effective Date

A handwritten signature in black ink, reading 'Doyle Childers'.

Doyle Childers, Director, Department of Natural Resources
Executive Secretary, Clean Water Commission

May 25, 2011
Expiration Date

Mike Struckhoff, Director, St. Louis Regional Office

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS					PAGE NUMBER 2 of 4	
					PERMIT NUMBER MO-0121975	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
(OUTFALL NUMBER AND EFFLUENT PARAMETERS)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>OUTFALL #001</u>						
Rainfall	inches	*		*	Daily	Measurement
Flow	MGD	*		*	Once/ Month	Estimate
Ph - Units	SU	***		***	Once/ Quarter**	grab
Total Suspended Solids (TSS)	mg/L	80		60	Once/ Quarter**	grab
Chemical oxygen Demand (COD)	mg/L	120		90	Once/ Quarter**	grab
Settleable Solids	mL/L/hr	1.5		1.0	Once/ Quarter**	grab
Total Dissolved Solids	mg/L	*		*	Once/ Quarter**	grab
Conductivity	µmhos/cm-25°C	*		*	Once/ Quarter**	grab
Total Petroleum Hydrocarbons (volatile)	mg/L	10		10	Once/ Quarter**	grab
Total Petroleum Hydrocarbons (semi-volatile)	mg/L	10		10	Once/ Quarter**	grab
Oil & Grease	mg/L	15		10	Once/ Quarter**	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE <u>OCTOBER 28, 2006</u> .						
<u>OUTFALL #001</u> (continued)						
Total Hardness	mg/L	*		*	Annually****	grab
Arsenic, Total Recoverable	mg/L	*		*	Annually****	grab
Chromium, Total Recoverable	mg/L	*		*	Annually****	grab
Copper, Total Recoverable	mg/L	*		*	Annually****	grab
Mercury, Total Recoverable	mg/L	*		*	Annually****	grab
Lead, Total Recoverable	mg/L	*		*	Annually****	grab
Beryllium, Total Recoverable	mg/L	*		*	Annually****	grab
Silver, Total Recoverable	mg/L	*		*	Annually****	grab
Zinc, Total Recoverable	mg/L	*		*	Annually****	grab
THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS. MONITORING REPORTS SHALL BE SUBMITTED <u>ANNUALLY</u> ; THE FIRST REPORT IS DUE <u>JANUARY 28, 2007</u> .						
B. STANDARD CONDITIONS						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED Parts I & III STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (Continued)

- * Monitoring requirement only.
- ** Sample once per quarter during the months of February, May, August and November.
- *** pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0 to 9.0 pH units.
- **** Sample once per year during the month of September.

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - a. Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - b. Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
 - c. Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.
2. All outfalls must be clearly marked in the field.
3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.
4. Changes in Discharges of Toxic Substances.

The permittee shall notify the Director as soon as it knows or has reason to believe:

 - a. That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
 - b. That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
 - c. That the effluent limit established in part A of the permit will be exceeded.
6. Water Quality Standards.
 - a. Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
 - b. General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (5) There shall be no significant human health hazard from incidental contact with the water;
 - (6) There shall be no acute toxicity to livestock or wildlife watering;
 - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

C. SPECIAL CONDITIONS (continued)

7. Report as no-discharge when a discharge does not occur during the report period.
8. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities
 - a. Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
 - b. If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.
8. Activities performed to control erosion on the landfill site, i.e. mulching, seeding, terracing, etc., shall be described and submitted with the second (May) and fourth (November) quarter monitoring data reports. If erosion controls were not required and not performed, indicate "erosion controls were not necessary, or performed" on the report.